

***Germano Water System***  
**Drinking Water Consumer Confidence Report**  
**For 2024**

## **Introduction**

The Germano Water System has prepared the following report to provide information to you, the consumer, on the quality of our drinking water. Included within this report is general health information, water quality test results, how to participate in decisions concerning your drinking water and water system contacts.

## **Source Water Information**

The Germano Water System receives its drinking water from groundwater from an aquifer located south of Germano on Township Road 147, Mill Road. We have one well that produces approximately thirty-six thousand gallons a day. The treatment process consists of chlorination and a filtration process. Which removes iron and manganese from your water. We have a connection with a Village of Jewett, if an emergency should arise in either jurisdiction. This connection was not utilized in 2024.

## **Susceptibility Analysis**

This assessment indicates that Germano's source of drinking water has a moderate susceptibility to contamination due to the presence of a moderately thick protective layer of clay/shale overlaying the aquifer, no evidence to suggest that ground water has been impacted by any significant levels of chemical contaminants from human activities, and the presence of numerous potential contaminant sources in the protection area. This susceptibility means that under current existing conditions, the likelihood of the aquifer becoming contaminated is moderate. This likelihood can be minimized by implementing appropriate protective measures. This susceptibility analysis is subject to revision if new potential contamination sources are sited within the protection area, or if water sampling indicates contamination by a manmade source. For further assistance on drinking water source protection, please contact the Harrison County water office at 740-942-0411.

## **What are sources of contamination to drinking water?**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife; (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; (D) Organic chemical contaminants, including synthetic

and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; (E) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, USEPA prescribes regulations which limit the number of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Federal Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

### **Who needs to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

### **About your drinking water.**

The EPA requires regular sampling to ensure drinking water safety. The Germano Water System conducted sampling for bacteria, nitrate, inorganic, disinfection byproducts, copper and lead, iron, and manganese during 2024. The Ohio EPA requires us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, are more than one year old.

## Table of Detected Contaminants

Listed below is information on those contaminants that were found in the Gremano drinking water.

**TABLE OF DETECTED CONTAMINANTS**

Contaminants (Units)	MCLG Or MRDLG	MCL,T,OR MRDL	Level Found	Range of Detections	Violation	Sample Year	Typical Source of Contaminants
<b>Radioactive Contaminants</b>							
Alpha emitters (pCi/L)	0	15	1.56+/- 1.61	NA	No	2021	Erosion of natural deposits
Radium	0	5	0.0221 +/-0.339	NA	No	2021	Erosion of natural deposits
<b>Inorganic Contaminants</b>							
Barium(ppm)	2	2	0.017	NA	No	2024	Discharge of drilling wastes
Chromium	0.1	0.1	0.00185	NA	No	2024	Discharge of drilling wastes
Nitrite(measure as Nitrogen)(ppm)	1	1	0.10	NA	No	2021	Runoff from fertilizer use leaching from septic tanks, sewage, Erosion of natural deposits
Nitrate(measure as Nitrogen)(ppm)	10	10	0.241	NA	No	2024	Runoff from fertilizer use leaching from septic tanks, sewage, erosion of natural deposits
Selenium(ppb)	50	50	1.71	NA	No	2024	Discharges from petroleum and metal refineries, erosion of natural deposits, discharge from mines
<b>Synthetic Organic Contaminants including Pesticides and Herbicides</b>							
<b>Volatile Organic Contaminants</b>							
Tetrachloroethylene(ppb)	0	5	0.5	NA	No	2021	Discharge from factories and dry cleaners
Haloacetic Acids(HAA5)(ppb)	NA	60	3.6	NA	No	2024	By-product of drinking water
Total Trihalomethane(THMs)(ppb)	NA	80	3.12	NA	No	2024	By-product of drinking water
<b>Residual Disinfectants</b>							
Total Chlorine(ppm)	4	4	0.5	0.4-0.7	No	2024	Water additive used to control microbes

Lead and Copper						
Contaminants (units)	Action Level (AL)	Individual Results over the AL	90% of test levels were less than	Violation	Year Sampled	Typical source of Contaminants
Lead (ppb)	15 ppb	0	1.00	No	2024	Corrosion of household plumbing systems
	_0_ out of _5_ samples were found to have lead levels in excess of the lead action level of 15 ppb.					
Copper (ppm)	1.3 ppm	0	0.03115	No	2024	Corrosion of household plumbing systems
	_0_ out of _5_ samples were found to have copper levels in excess of the copper action level of 1.3 ppm.					

### Lead Educational Information

Per the Lead and Copper rules, public water systems are required to develop and maintain a service line inventory. A service line is the underground pipe that supplies water to your home or building with water. To view the service line inventory, which lists the material types for your location, you can view this by going to [harrisoncountyohio.gov](http://harrisoncountyohio.gov) click on departments select county water tab, then look for heading service inventory and select your water system name.

### License to Operate (LTO) Status Information

In 2024 we had an unconditional license to operate our water system.

### Public Participation and Contact Information

Public participation and comment are encouraged at regular meetings of the Harrison County Water Board which meets the first Tuesday of each month. For more information on your drinking water contact Steve Rocknich at 740-942-0411 or 740-491-0183

### Definitions of some terms contained within this report.

- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant level (MCL): The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.
- Parts per Million (ppm) or Milligrams per Liter (mg/L) are units of measure for concentration of a contaminant. A part per million corresponds to one second in a little over 11.5 days.
- Parts per Billion (ppb) or Micrograms per Liter (µg/L) are units of measure for concentration of a contaminant. A part per billion corresponds to one second in 31.7 years.
- The "<" symbol: A symbol which means less than. A result of <5 means that the lowest level that could be detected was 5 and the contaminant in that sample was not detected.
- Picocuries per liter (pCi/L): A common measure of radioactivity.